

PRODUCT ANNOUNCEMENT**Photocell FZ 711S is now obsolete**

There are three replacement scenarios. They are as follows:-

1. Where the 40001 FZ 711S is being used with the TF 801 and TF 802 series of oil burner controls, it is necessary to change the control box to the 02431U TF 832.3 and fit the 50001 MZ 770S photo-cell and 59101 mounting flange.

The 50001 MZ 770S uses the same lead as the 40001 FZ 711S, but is also available as SAT PACK MZ 500MM.

2. Where the 40001 FZ 711S is being used with the TMO 720 220/240V series of burner controls, it is necessary to change the photo-cell to the 16503 IRD 1010 infra-red flicker detector and 7231001 1.0m cable and plug. *CZ1689N*

3. Where the FZ 711S is being used with the TMO 720 110V series of burner controls, there is no replacement flame detector.

We can recommend changing the control box to the 08223U TMG 740-3 Mod 43-35 110V control box, 70205U S720G wiring base, 2 x 70503 cable entry plate and the 18813U UVZ 780 Red UV scanner and 18807 UV flange. The wiring base is available as SAT PACK S720G and the UV cell as SAT PACK UV RED.
